



Karnataka Fire and Emergency Services Department

Office of the Chief fire officer,

Bangalore west zone, High-ground fire station premises,

Sheshadri road, Bangalore - 560 009.

080 - 22971523 / 500 / 600. Fax : 080 - 22971523.



No. ¹³⁴ /ADV/CFO/BWZ/2024

22-05-2024

To,
The Chairman,
Sri Togataveer Sanjeev Educational
and Welfare Society (R),
Delhi Central School,
Plot No. 01 of R. Sy. No. 844/1+2+3+4
& 844/H, Hunasikkatte road,
Ranebennur Town & Taluk,
Haveri District.

Sir,

Sub : Issue of 'Fire safety advice certificate' to Sri Togataveer Sanjeev Educational & Welfare Society (R), Delhi Central School, Plot No. 01 of R.Sy. No. 844/1+2+3+4 & 844/H, Hunasikkatte road, Ranebennur Town & Taluk, Haveri District.

Ref: Your letter Dated 15-05-2024

*** **

With reference to the subject above cited, the premises of *Sri Togataveer Sanjeev Educational & Welfare Society (R), Delhi Central School* situated at Plot No. 01 R.Sy. No. 844/1+2+3+4 & 844/H, Hunasikkatte road, Ranebennur Town & Taluk Haveri District was inspected by Regional Fire Officer, Davangere Range (18-05-2024 with respect to Fire prevention, Fire fighting and Evacuation measures be complied in the above premises and has submitted the details as under;

A. Details of the building / premises :-

01. Address of the premises : *Sri Togataveer Sanjeev Educational & Welfare Society (R), Delhi Central School*
Plot No. 01 of R.Sy. No. 844/1+2+3+4 & 844/H, Hunasikkatte road,
Ranebennur Town & Taluk,
Haveri District.



02. Number of building : One building only.
 03. Number of floor : Basement & ground & 1st floor

04. Floor-wise details of occupancy :-

Basement floor : Mathematics lab, Computer lab and store room.

Ground floor : Office room, head master room, staff room & 06 class rooms.

1st floor : Office room, head master room, staff room & 06 class rooms.

05. Type of construction : RCC building.

06. Height of the building : 08.17 mtrs.

07. Site area : 8092.74 Sq.mtrs.

08. Built up area of each floor :-

Basement floor : 157.00 Sq.Mtrs.

Ground floor : 782.78 Sq.Mtrs.

1st floor : 782.78 Sq.Mtrs.

09. Total built-up area : 1722.56 Sq.Mtrs.

10. Number of students : Student - 279 numbers
 Teaching Staffs - 12 members
 Non teaching staffs - 07 members.

11. Surrounding properties :-

East (S) : 06.00 mtrs wide road thereafter private property.

West (S) : 24.00 mtrs wide road thereafter private property.

North (R) : Owner property.

South (F) : School play ground thereafter private property.



12. Name and address
of the building owner

The Secretary,
Sri Togataveer Sanjeev Educational &
Welfare Society (R),
Delhi Central School
Plot No. 01 of R.Sy. No. 844/1+2+3+4 &
844/H, Hunasikkatte road,
Ranebenmur Town & Taluk,
Haveri District.

13. Name and address
of applicant

The Chairman,
Sri Togataveer Sanjeev Educational &
Welfare Society (R),
Delhi Central School
Plot No. 01 of R.Sy. No. 844/1+2+3+4 &
844/H, Hunasikkatte road,
Ranebenmur Town & Taluk,
Haveri District.

B. On inspection of the school premises, the following fire prevention, fire fighting & evacuation measures are recommended and are absolutely essential:-

Sl. No.	Details [02]	Existing [03]	Recommendations [04]
01.	Approach to the premises	The premises is accessible from 24.00 mtrs wide Hunasikkatte village road located on the western side and 06.00 mtrs wide service road located on the eastern side both the roads are hardened to carry the weight of 45,000 kgs.	The requirement is complied with
02.	Number of staircases.	2 staircases, each of 2.50 mtrs width have been provided from ground floor to an upper floor.	Adequate



One separate staircase, of 0.90 mtrs width has been provided from ground floor to basement floor.

03. Number of entrances

2 entrances, One of 05.50 mtrs located on western side & another one of 03.00 mtrs width located on Eastern side of the premises.

Adequate

04. Width of open space

East : -Nil-
West : 10.00 mtrs.
North : Min 30.00 mtrs.
South : Min 10.00 mtrs

The allowed setbacks all around the building shall be kept free from any further construction and obstruction for the easy movement of emergency vehicle.

05. Portable extinguishers.

Not provided 1. 01 ABC fire extinguishers of 6 kgs. capacity in the each laboratory if provided.

2. 01 ABC type fire extinguishers of 6 kgs. capacity and 2 sand buckets shall be provided near each electrical panel board, electrical sub main board, near the generator and in the lift machine room.

3. 2 ABC fire extinguishers shall be provided in corridor of the building.

4. One ABC fire extinguisher of 6 kgs capacity shall be provided inside the all class rooms.



- | | | |
|---|--|---|
| 06. Escape routes | Not displayed | Direction in which the students have to move in the event of an emergency should be indicated in the corridor during evacuation. And it should be written in luminous paint. |
| 07. Hose reel hose | Not provided | An hose reel hose system of 19 mm dia and having a length of 36.50 mtrs length shall be installed by tapping them to a vertical pipe of 80 mm internal dia, near the main staircase with outlets at each floor. The hose reel hose system should be connected to an over-head tank of 10,000 ltrs capacity with a pump capable of delivering of 450 ltrs of water per minute. |
| 08. First aid boxes. | 05 nos first aid box have been provided in each floor of the building. | Adequate |
| 09. Fire order
[Fire safety plans] | A notice board indicated the action should be taken by the employees in case of any emergency with the telephone number of Ranebennur fire station i.e 08373-269101 & 101 and the telephone number of nearest ambulance service. | Adequate |



- | | | |
|----------------------------|-------------|---|
| 10. Fire fighting training | Not trained | At least 40% of staffs should be trained in basic fire fighting system in R.A. Mundkar Fire and Emergency Services Academy, Banneru-ghatta road, Bangalore - 560 029 within 6 months or at an early date. |
|----------------------------|-------------|---|

11. Fire precautionary measures: -

- A. The exit ways shall be kept clear always without any obstructions.
- B. The exit ways shall be marked with using illuminating paint.
- C. No fire in any form shall be used in the premises.
- D. Inflammable and explosive materials shall not stored in the area.
- E. 'No Smoking' boards shall be displayed at appropriate places in the premises.
- F. 2 emergency lights covering the floors shall be installed.
- G. The doors shall not be kept locked / latched during working hours.

Under the above circumstance the Karnataka Fire & Emergency Service Department is issuing 'Fire Safety Advice Certificate' to *Sri Togataveer Sanjeev Educational & Welfare Society (R), Delhi Central School* situated at Plot No. 01 of R.Sy. No. 844/1+2+3+4 & 844/H, Hunasikatte road, Ranebennur Town & Taluk, Haveri District subject to condition and compliance of the above recommendations in column -3 of serial - B within 3 months and compliance to the undersigned, if failed, this 'Advice certificate' will be cancelled.

This 'Advice Certificate' is issued for a period of only one year from the date of issue and is renewable.


Chairman
Delhi Central School
 Hunasikatti Road, Vidyagiri
 Ranebennur-581110


Principal
DELHI CENTRAL SCHOOL
 RANE BENNUR-581110

Yours faithfully

Chief Fire Officer
 Bangalore West, Sheshadri Road,
 Highground Fire Station Premises,
 Bangalore - 560 009.