

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. CMCRNR/Health/CR-01/2024-25

Dated: 28/06/2024

It is certified that an inspection team headed by ARE (Environment)

(Name of Officers with designation) from PHED

inspected the Delhi Central School

(Name & Address of the school) on 28/06/24 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. STJ/CEP/IR/2024-25/10 dated 29-06-2024

of STJ Institute of Technology (PHED Lab) certified that the

Delhi Central School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 27/06/2025

Signature with Seal: [Signature]
Name: Kodabata Maheshwara
Designation: Assistant Executive Engineer (Env)
Name & Address of the Office/ Department: Office, Department, Ranebennur

To Delhi Central School
Hunasikatti Road, Ranebennur - 581115
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Self attested by
[Signature]
Chairman

Delhi Central School
Hunasikatti Road, Vidyagiri
Ranebennur-581115

[Signature]
Chairman

Delhi Central School
Hunasikatti Road, Vidyagiri
Ranebennur-581115

[Signature]
Principal
DELHI CENTRAL SCHOOL
RANE BENNUR-581115



Sri Taralabalu Jagadguru Education Society ©, Sirigere

STJ INSTITUTE OF TECHNOLOGY, RANEBENNUR

Dist. Haveri, Karnataka, INDIA. Pin Code - 581115

(Approved by AICTE New Delhi and Affiliated to Visvesvaraya Technological University, Belagavi)

Phone : 08373-266343 / 262075 Fax : 08373-266427 principal@stjit.ac.in, www.stjit.ac.in

Estd. 1980

Department of Civil Engineering

STJ/CED/TR/2024-25/101

Date: 29.06.2024

TEST RESULTS

To,
Delhi Central School
Hunasikatti road
Ranebennur, Haveri

Sir,

Sub: Testing of Bore well Water- Reg

Location: Water testing for Delhi Central School bore well water. Hunasikatti road,
Ranebennur, Haveri Dist.

| Sl No | Particulars | Test Results | Tolerable Limits |
|-------|--------------------------|------------------|------------------|
| 1 | pH | 7.12 | 6.5 - 8.5 |
| 2 | Temperature °C | 14 | 10 - 20 |
| 3 | Taste and odour | Un objectionable | Un objectionable |
| 4 | Turbidity (NTU) | 6 | 5 - 25 |
| 6 | Total Hardness (ppm) | 450 | 300 - 600 |
| 7 | Calcium Hardness (ppm) | 90 | 75 - 200 |
| 8 | Magnesium Hardness (ppm) | 360 | 30 - 1000 |
| 9 | Chloride Content (ppm) | 210 | 250 - 1000 |

This Sample is fit for Drinking Purpose.

Note: This report is strictly confidential. Its use for publicity, arbitration or evidence in legal disputes is forbidden.

Staff In charge

Head of Department
Department of Civil Engineering
S.T.J. Institute of Technology
RANEBENNUR-581115
Haveri (Dist) Karnataka

Chairman

Delhi Central School
Hunasikatti Road, Vidyagiri
Ranebennur-581115

Principal

DELHI CENTRAL SCHOOL
RANEBENNUR-581115